

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

Dated: 17/05/2023

No.

It is certified that an inspection team headed by Prabhat Ranjan (Chemist./Lab Incharge)
 (Name of Officers with designation) from Uttar Pradesh Jal Nigam (Rural) Kushinagar
 (Name of Department/ Office) inspected the St. Xavier School, Pakhsiyati, Tamkuhi Road, Seorahi, Kushinagar
 (Name & Address of the school) on 17/05/2023 (date of inspection) and found that the
St. Xavier School, Seorahi, Kushinagar (Name of school) has safe drinking water
 facilities for the students and members of staff of the institution and is maintaining the hygienic
 sanitation condition in the school building & the campus as per norms prescribed by the Central/
 State/ U.T. Govt.

The above is valid for a period of 1 year.....

Signature with Seal:

Name

Designation

Name & Address of the Office / Department : Uttar Pradesh
 Jal Nigam (Rural) Kushinagar
 Uttar Pradesh.

To

St. Xavier School
Pakhsiyati, Tamkuhi Road, Seorahi
Kushinagar
 (Name & Address of the Institution)

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.

Sueena Choudhary

Manager
 St. Xavier's School
 Tamkuhi Road, Kushinagar

[Signature]
 Principal
 St. Xavier's School
 Tamkuhi Road, Kushinagar



कार्यालय अधिशासी अभियन्ता खण्ड कार्यालय उ० प्र० जल निगम (ग्रामीण)
पडरौना कुशीनगर ।
जनपदीय जल विश्लेषण प्रयोगशाला

नमूना संग्रहकर्ता	नमूना संग्रहण दिनांक	Tested Parameters	युग्म	आयतन	माईट्रिट	आर्सेनिक	फ्लोराईड	क्लोराईड	डी०डी०एस	एल्केनिटी	सल्फेट	पी०एच०	मंघामन	संग्रह कर्ता	संक्रामक प्रदूषण		रिजर्वी											
														ppm	Total Coliform	E-Coli												
नमूना संग्रहण दिनांक		Unit Of Measurement	Agreeable	1	45	0.01	1	250	500	200	200	6.5-8.5	1	ppm	0	0												
		Desirable Limit												Disagreeable	1	45		0.01	1.5	1000	2000	600	400	6.5-8.5	5	600	0	0
		Permissible Limit																										
नमूने की स्थिति	प्रत्येक जल की मात्रा		IS:3025 (Part 5)	IS:3025 (Part 53)	IS:3025 (Part 34)	IS:3025 (Part 37)	IS:3025 (Part 60)	IS:3025 (Part 32)	IS:3025 (Part 16)	IS:3025 (Part 23)	IS:3025 (Part 24)	IS:3025 (Part 11)	IS:3025 (Part 10)	IS:3025 (Part 21)														
क्र० सं०	जनपद	विकास खण्ड	लोकेशन		श्रोत का नाम																							
1	कुशीनगर	Seorahi	St. Xavier School		विद्यालय का पानी	गंधहीन	0.1	7.45	0	0.2	45	134	162	92	7	2.34	98	0	0	संतोषजनक								

Note-

1. This certificate refers only to the particular sample (s) submitted for testing
2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from head of laboratory.
3. The test results reported in this certificates are valid at the time of and under the stated conditions of measurements



अधिशासी अभियन्ता
अधिशासी अभियन्ता
खण्ड कार्यालय
उ० प्र० जल निगम (ग्रामीण)
कुशीनगर

Sneha Chaudhary
Manager

St. Xavier's School
Tamkuhi Road, Kushinagar

[Signature]
Principal

St. Xavier's School
Tamkuhi Road, Kushinagar